

FIELD TERMINATION PLUG USER GUIDE

FP

1

COPPER FOIL TAPE
30MM x 10MM

SR-A OR SR-B

2

BOOT
CABLE

3

S/FTP OR U/FTP.F/UTP

4

COPPER FOIL TAPE

5

WRAPPED UP

6

7

8

5-8MM MAX.

9

10 CUT FRONT ROW WIRES FLUSH

CUT 2
CUT 1
0.2MM MAX.

11

12a

CLICK

12b OPTIONAL ETC(EASY TOOL TO CRIMP) TOOL

13

OK NG

14

15

LEGEND

W WHITE
G GREEN
O ORANGE
BL BLUE
BR BROWN

PIN ASSIGNMENT T568A

1	2	3	4	5	6	7	8
W-G	G	W-O	BL	W-BL	O	W-BR	BR

PIN ASSIGNMENT T568B

1	2	3	4	5	6	7	8
W-O	O	W-G	BL	W-BL	G	W-BR	BR

CABLE INFORMATION FOR INSTALLATION

	TYPE	CONDUCTORS	WIRE OD(MM)	CABLE OD(MM)
C6A	23~26AWG	STRANDED & SOLID	1.0-1.4	6.0-8.5
C6A	22~24AWG		1.2-1.5	
C8	22~24AWG		1.2-1.7	