

BRAILLE SIGN INSTALLATION TO D3.6 SPECIFICATION

1. Scope

This specification sets out the requirements for the design and installation of Braille and Tactile Signage as required by D3.6.

2. Location of Braille and Tactile Signs

Signs including symbols, numbering and lettering must be designed and installed as follows:

- a. Braille and Tactile components of a sign must be located not less than 1200mm and not higher than 1600mm above the floor or ground surface.
- b. Signs with single lines of characters must have the line of tactile characters not less than 1250mm and not higher than 1350mm above the floor or ground surface.
- c. Signs identifying rooms containing features of facilities listed in D3.6 must be located:
 - i. On the wall on the latch side of the door with the leading edge of the sign located between 50mm and 300mm from the architrave ; and
 - ii. Where (i) is not possible, the sign may be placed on the door itself.

