

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing

A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Test Number : 17-007361

Issue Date : 11/04/2018

Print Date : 11/04/2018

Order Number : 4616

Sample Description Clients Ref : "Industry Flex and Premium Flex/Acoustic Duct"
300mm diam R1.0 Insulated Flexible duct, metalised inner core, metalised outer sleeve

UL 181.13-2013

Mould Growth and Humidity Test - Air Duct

Mould Used Chaetonium Globosium

Did Mould spread beyond the Inoculated area ? No

Did structural material become deformed or delaminated ? No

Compliance to ASNZS 4254.1-2012 Clause 2.4.2 Complies

Tested at Silliker Microtech

Test Report No. 454352572

Three samples of each component submitted were tested.

Observation: Slight discolouration on the silver surface

125248

24851

Page 1 of 1

© Australian Wool testing Authority Ltd
Copyright - All Rights Reserved

Samples, and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. The above test results are designed to provide THE CLIENT WITH GUIDANCE INFORMATION ONLY.

This document shall not be reproduced except in full and shall be rendered void if amended or altered.

This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved in advance by the Managing Director of AWTA Ltd.



APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc.(Hons)
MANAGING DIRECTOR