



Professional Scientific Solutions

VOC Content Test Certificate

Wednesday May 17 2023

Supplier: Macsim Australia Pty Ltd (10 Wonderland Drive, Eastern Creek, NSW 2766)

Sample Description: Macsim Ductseal

Date Tested: October 2009 (Tested by FORAY Laboratories - NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Macsim Ductseal
Architectural Sealant 250 grams per Litre as VOC content material	7 grams per Litre , less water and exempt solvents (South Coast Air Quality Management rule 1168) as voc content material
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Macsim Ductseal
Architectural Sealant 250 grams per Litre as VOC content material	7 grams per Litre , less water and exempt solvents (South Coast Air Quality Management rule 1168) as voc content material

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0910-08b