



Professional Scientific Solutions

VOC Content Test Certificate

Wednesday March 17 2023

Supplier: Macsim Fastenings Pty Ltd (10 Wonderland drive, Eastern Creek NSW 2765 Australia)

Sample Description: Macsim Roof and Gutter Silicone (translucent)

Date Tested: March 2010 (Tested by FORAY Laboratories - NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Macsim Roof & Gutter Silicone (translucent)
VOC content material	40 grams per Litre as VOC content material
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Macsim Roof & Gutter Silicone (translucent)
VOC content material	40 grams per Litre as VOC content material

F1003-12

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

CETEC Pty Ltd

ABN 44 006 873 687

W: www.cetec-foray.com.au

2/27 Normanby Rd, Notting Hill, VIC 3168 Australia - T: +6139544 9111 - F: +613 9544 9122 • E: info@cetec-foray.com.au

165 Nicholson St, St Leonards, NSW 2065 - T: +612 99669211 - F: +612 9966 9210 - E: sydney@cetec-foray.com.au