

VOC Content Test Certificate

Wednesday March 17th, 2023

Supplier: Maccsim Fastenings Pty Ltd (10 Wonderland drive, Eastern Creek NSW 2765 Australia)

Sample Description: Maccsim Roof and Gutter Silicone (Black, translucent, Aluminum, White)

Date Tested: March 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11</p>	<p align="center">Maccsim Bathroom</p> <p align="center">And Kitchen Sanitary</p> <p align="center">(Black, translucent, Aluminum, White)</p>
<p>Architectural Sealant 250 grams per Litre as VOC content material</p>	<p align="center">75 grams per Litre as VOC content material</p>
<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V3 IEQ-13</p>	<p align="center">Maccsim Bathroom</p> <p align="center">And Kitchen Sanitary</p> <p align="center">(Black, translucent, Aluminum, White)</p>
<p>Architectural Sealant 250 grams per Litre as VOC content material</p>	<p align="center">75 grams per Litre as VOC content material</p>



F1003-12

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant