

Conductor marking collar - UCT-WMS 3,2 (12X4) - 0828570

Please be informed that the data shown in this PDF Document is generated from our Online Catalog. Please find the complete data in the user's documentation. Our General Terms of Use for Downloads are valid (http://phoenixcontact.com/download)



Conductor marking collar, Sheet, white, unlabeled, can be labeled with: TOPMARK NEO, TOPMARK LASER, BLUEMARK ID COLOR, BLUEMARK ID, BLUEMARK CLED, THERMOMARK PRIME, THERMOMARK CARD 2.0, THERMOMARK CARD, mounting type: slide-on, for terminal block width: 5.2 mm, cable diameter range: 1.5 ... 3.2 mm, lettering field size: 12 x 4 mm, Number of individual labels: 55

Your advantages

- The UCT-WMS ... UniCard labeling range includes markers that can be threaded onto conductors

- The format automatically ensures printing with a high degree of positioning accuracy



Key Commercial Data

Packing unit	8 pc
Minimum order quantity	8 pc
GTIN	4 046356 519670
GTIN	4046356519670
Weight per Piece (excluding packing)	12.520 g
Custom tariff number	39199000
Country of origin	Poland
Sales Key	BG2218

Technical data

Dimensions

Length (b)	12 mm
Width (a)	4.3 mm
Height (c)	5.8 mm
Cable diameter	1.5 mm 3.2 mm

Ambient conditions



Conductor marking collar - UCT-WMS 3,2 (12X4) - 0828570

Technical data

Ambient conditions

Ambient temperature (operation)	-40 °C 120 °C
I Recommended storage conditions	23 °C/50 % relative humidity. Storage in a dry and dark place in the original packaging is recommended.

General

Note	Can be labeled via thermal transfer
Color	white
Туре	Card form
Components	free from silicone and halogen
Flammability rating according to UL 94	V0
Material	PC V0
RoHS compliant	Yes
Wipe resistance	DIN EN 61010-1 (VDE 0411-1)
Number of individual labels	55
Number of individual labels per row	11
Test for substances that would hinder coating with paint or varnish	VW PV 3.10.7:2005-02
Result	Test passed
Test specification weathering-resistance	Following ISO 4892-2:2013-03
Test duration	96 h
Result of weather resistance test	Test passed
Salt spray test specification	DIN EN 60068-2-11:2000-02
Test duration	96 h
Salt spray testing result	Test passed
Wipe resistance of test specification inscriptions	DIN EN 61010-1 (VDE 0411-1):2011-07
Result of wipe resistance test	Test passed
Marking mounting type	slide-on
Result	Test passed
Oxygen index (DIN EN ISO 4589-2)	32.4 %
R22	HL 1 - HL 3
R23	HL 1 - HL 3
R24	HL 1 - HL 3

Standards and Regulations

Wipe resistance	DIN EN 61010-1 (VDE 0411-1)
Flammability rating according to UL 94	V0

Environmental Product Compliance

China RoHS	For details about hazardous substances go to tab "Downloads", Category "Manufacturer's declaration"
------------	---