

Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

Company Name	Zhejiang Ruihua Machinery Co., Ltd	Client ID	102557
Company Other Name		Type of Certification	Product Certification; System 5
Certification Standard	AS/NZS 1841.3-2007 : Portable fire extinguishers - Specific requirements for wet chemical type extinguishers		
Certification Review Date	19/09/2014	Certification Expiry Date	19/09/2019
Certificate Issue Date	9/05/2015	Certificate Last Update Date	

APPROVED COMPANY/SITE ADDRESS(ES):

Western Industrial Zone, Lingshan Town Yuyao 315460 Zhejiang China

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager



Unique Certificate Code: EB06706B8131A80ACA257DF70082C7F6

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®





global-mark®

Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:

In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
WC20	2.0 L Wet Chem type extinguisher	Presto	2.0 L wet chem type, Rating: 2A:4F, FERN: 2557.03-100	9/05/2015
WC20	2.0 L Wet Chem type extinguisher	FireWorld	2.0 L wet chem type, Rating: 2A:4F, FERN: 2557.03-200	9/05/2015
WC20	2.0 L Wet Chem type extinguisher	No name	2.0 L wet chem type, Rating: 2A:4F, FERN: 2557.03-300	9/05/2015
WC70	7.0 L Wet Chem type extinguisher	Presto	7.0 L wet chem type, Rating: 3A:4F, FERN: 2557.03-101	9/05/2015
WC70	7.0 L Wet Chem type extinguisher	FireWorld	7.0 L wet chem type, Rating: 3A:4F, FERN: 2557.03-201	9/05/2015
WC70	7.0 L Wet Chem type extinguisher	No name	7.0 L wet chem type, Rating: 3A:4F, FERN: 2557.03-301	9/05/2015

Comments:

Extinguisher construction complies with AS/NZS 1841.1 standard requirements.

End of the document



Certification Manager