



Powering Business Worldwide

SUPPLIER DECLARATION OF CONFORMITY (SDoC)

In accordance with ISO/IEC 17050-1:2004

SDoC Identification Number¹:

Issuer details

Name ² (of New Zealand manufacturer or importer): <input type="text" value="Eaton Industry Company"/>	Contact Address: <input type="text" value="106 Wrights Road
Addington
Christchurch 8024
New Zealand"/>
Telephone: <input type="text" value="0064 3 343 3314"/>	
New Zealand Company No. (if applicable): <input type="text" value="284932"/>	
Email Address: <input type="text" value="dcinfo@eaton.com"/>	

Medium Risk Article – Details³ (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable):

ACD15M-00 fitted 1x16A input MCB, and 1x16A output MCB, Earth and Neutral Bar with MEN Link.

Rating: AC Voltage: 230V, 1P+N+PE, 50HZ, 16A

Application: It can be only used as the output distribution of Eaton Matrix Inverter,

The Medium Risk Article listed above, fully complies:

With cited standard(s), as listed⁴:	
Standard number and issue year: <input type="text" value="AS/NZS 3820"/>	Standard number and issue year: <input type="text" value="AS/NZS3000:2007"/>
Edition / Amendment status: <input type="text" value="Incorporating Amendment 1"/>	Edition / Amendment status: <input type="text" value="Incorporating Amendment 2"/>
Standard title: <input type="text" value="Essential safety requirements for low voltage electrical equipment"/>	Standard title: <input type="text" value="Electrical Installation"/>
AS/NZS ZZ modified Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	AS/NZS ZZ modified Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input checked="" type="checkbox"/>
OR Complies with the Conformity Cooperation Agreement ⁵ Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	

Names and addresses of any testing organisation or body

Name(s): Address(es):


Reference to relevant test reports/certification and the issue date that show how compliance is achieved

Standard(s) or document(s) used, to show how compliance with cited standard is	Report Certification or Document Reference No.	Issue date(s):
Product Wiring Diagrams	NZWD-000092 Rev1	Oct 2016
Final test	Normal safety test: Electrical strength, insulation resistance & Earth continuity required with test label attached to ACD	
BOM	OP-ACD15M-00	Latest in Enovia

Reference to any management quality system involved:

Additional information⁶:

Declaration (signed for and on behalf of)

Name and position as authorized by the issuer ⁷ : <input type="text" value="Hugh Moore
Engineering Manager"/>	Signature: 
Issuer Identification (as affixed to the article): <input type="text" value="Eaton Corporation"/>	Date: <input type="text" value="27-3-2019"/>