

**SDoC Identification Number<sup>1</sup>:**

**Issuer details**

Name <sup>2</sup> (of New Zealand manufacturer or importer): <input type="text" value="Eaton Industry Company"/> Telephone: <input type="text" value="0064 3 343 3314"/> New Zealand Company No. (if applicable): <input type="text" value="284932"/> Email Address: <input type="text" value="dcinfo@eaton.com"/>	Contact Address: <input type="text" value="106 Wrights Road&lt;br/&gt;Addington&lt;br/&gt;Christchurch 8024&lt;br/&gt;New Zealand"/>
--	---

**Medium Risk Article – Details<sup>3</sup> (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable):**

**EATON CSFI CLASSII /Cat B &A, Din Rail Compact Surge Filter**

**Rating:** Class II/Cat B, 6kV/3kA Major sub mains & Short final sub circuits  
 Class II/Cat A, 6kV/200A Long final sub circuits & power outlets

**The Medium Risk Article listed above, fully complies:**

<b>With cited standard(s), as listed<sup>4</sup>:</b> Standard number and issue year: <input type="text" value="AS/NZS 3820:2009"/> Edition / Amendment status: <input type="text" value="Incorporating Amendment 1"/> Standard title: <input type="text" value="Essential safety requirements for low voltage electrical equipment"/> AS/NZS ZZ modified Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	Standard number and issue year: <input type="text" value="AS/NZS3100:2017"/> Edition / Amendment status: <input type="text" value="Incorporating Amendment 2"/> Standard title: <input type="text" value="Approval and test specification - General requirements for electrical equipment"/> AS/NZS ZZ modified Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input checked="" type="checkbox"/>
<b>OR Complies with the Conformity Cooperation Agreement<sup>5</sup></b> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	

**Names and addresses of any testing organisation or body**

Name(s): <input type="text" value="Ente Certificazione Macchine Srl"/>	Address(es): <input type="text" value="Via Ca' Bella,243-Loc, Castello di Serravalle – 40053 Valsamoggia (BO)-Italy"/>
--	--

**Reference to relevant test reports/certification and the issue date that show how compliance is achieved**

Standard(s) or document(s) used, to show how compliance with cited standard is	Report Certification or Document Reference No.	Issue dates(s):
Certificate of Compliance	No. 00190708, PETQ 94	8 July 2019
Test Reports No.	DEU (19)-06-H1013S, DEU(19)-06-H1013E	21 June 2019
Quality Certificate	Issued by Prosurge Electronics Co., Ltd	21 May 2019
CSFi BOM and OQC	Supplied by Prosurge Electronics Co., Ltd	
Varistor voltage (V1mA) test Record	Supplied by Prosurge Electronics Co., Ltd	
Reference to any management quality system involved: <input type="text" value="ISO9001 Certificate of Prosurge Electronics Co.,Ltd"/>		
Additional information <sup>6</sup> : <input type="text" value="This product is manufactured by Prosurge Electronics Co., Ltd"/>		

**Declaration (signed for and on behalf of)**

<b>Name and position as authorized by the issuer<sup>7</sup>:</b> <input type="text" value="Frank Leung&lt;br/&gt;Engineering Manager"/>	<b>Signature:</b> <input type="text" value="Handwritten Signature"/>
<b>Issuer Identification (as affixed to the article):</b> <input type="text" value="Eaton Corporation"/>	<b>Date:</b> <input type="text" value="12-9-2019"/>